

Integrated Energy Systems Experimental Systems Development

Terry James Morton

September 2020



The INL is a U.S. Department of Energy National Laboratory
operated by Battelle Energy Alliance

Integrated Energy Systems Experimental Systems Development


Terry James Morton

September 2020

**Idaho National Laboratory
Idaho Falls, Idaho 83415**

<http://www.inl.gov>

**Prepared for the
U.S. Department of Energy
Under DOE Idaho Operations Office
Contract DE-AC07-05ID14517**



IES

Integrated Energy Systems

IES Experimental Systems Development

T.J. Morton

Plant Engineering Lead, Integrated Energy Systems

Idaho National Laboratory

terry.morton@inl.gov

Goals for Today

- High-level discussion of Integrated Energy Systems
- Overview of Dynamic Energy Transport and Integration Laboratory (DETAIL)
- Overview of Thermal Energy Distribution System (TEDS)
- Overview of Microreactor Agile Non-Nuclear Experimental Test Bed (MAGNET)

Integrated Energy Systems (IES)

...using energy efficiently and effectively...


“Right-sized” reactors offer new options for various community sizes and energy demands.



Large
Light Water
Reactors




Micro
Reactors



Small
Modular
Reactors



Advanced
Reactors




IES Offer a Key Opportunity for Energy System Flexibility

Nuclear is evolving into **a more flexible energy source** that can work alongside chemical plants and renewable generators to create integrated energy systems.

THE **FLEXIBILITY** OF NUCLEAR

PRODUCTS


Nuclear's **thermal energy** can be used to create many diverse products:




THE **FLEXIBILITY** OF NUCLEAR energy.gov/ne

elect
clear
hydro
heat
grids
vehicles
synthetic fuels
ammonia
metals refining
and more

MICROREACTOR
1 MW – 20 MW



SMALL MODULAR REACTOR
20 MW – 300 MW



LARGE SCALE REACTOR
300 MW – 1,000+ MW



SIZE

Nuclear has the **right-sized reactors** to meet the energy needs of any community.

THE **FLEXIBILITY** OF NUCLEAR

energy.gov/ne



IES
Integrated Energy Systems

LWR-H₂ Demonstration Projects: Exelon, USA




Partners: Nel Hydrogen, ANL, INL, NREL (via DOE)

Analysis Report: [Evaluation of Hydrogen Production for a Light Water Reactor in the Midwest](#)

Purpose & Scope:


1. Demonstrate hydrogen production using direct electrical power offtake from a nuclear power plant and acquaint plant operators with methods and controls for scaling up to large commercial plants.
2. Evaluate power offtake dynamics and inverter control response to provide grid contingency, ramping reserves, and volt/reactive control reserve.
5. Produce hydrogen for captive use by NPPs
6. Produce hydrogen for first movers of clean hydrogen; fuel-cell buses, heavy-duty trucks, forklifts, and industrial users



****Exelon will commence testing within 18-24 months at a to-be-announced LWR plant.**



LWR-H₂ Demonstration Projects: Davis Besse, Ohio, USA



Hydrogen
Production
Area

****Commence testing in 24-36 months.**



Electrical
Tie-In

Power
Block




***Industry Consortium of Energy
Harbor, Xcel Energy, Arizona
Public Service, DOE Labs***

The engineering design team will design and locate the hydrogen production equipment such that the effect on the design and licensing basis is mitigated (to the extent practical).


Analysis Report: [Evaluation of Non-electric Market Options for a Light-water Reactor in the Midwest](#)



Dynamic Energy Transport and Integration Laboratory (DETAIL)



Dynamic Energy Transport & Integration Lab (DETAIL)





Dynamic Energy Transport & Integration Lab (DETAIL)



TEDS


To begin initial operation in December 2020



TEDS Objectives

- **Performance analysis and demonstration of:**
 - Energy storage in charge and discharge modes
 - Energy storage in the context of integrated system operation strategy
 - Valves, flanges, instrumentation, and other associated components (such as gaskets, seals, filler materials) under steady-state and cycling modes
 - Distribution of thermal energy to and from various co-located systems, further providing information on the dynamic operation and characteristic time constants associated with moving thermal energy between systems of different sizes and heat requirements.
- **Develop and demonstrate** monitoring and control systems and to investigate real-time, hardware-in-the-loop **response characteristics** relative to grid operations. The system can be used to characterize thermal energy inertia and thermal energy management relative to the interoperability of a nuclear plant, power generation, and industrial heat applications.
- **Validate computational models** such as RELAP, Modelica, and other transient physics-based models that can support scale-up of integrated energy systems.
- **Demonstrate** transport/transmission characteristics and performance in a flexible and dynamic manner, such that the envisioned **operating modes** can be tested and performance verified.
- **Provide** a test platform to test standard regional grid operations and to experimentally simulate the buildout of potential future grids that may include excessive renewable (solar and wind) penetration.
- **Provide** an opportunity to experimentally **demonstrate grid stressors** that otherwise may not be simulated and see how such stressors may impact the generators in one-way feedback.
- **Support unattended operation** and provide a platform for **demonstrating** safe shutdown procedures.
- Provide a test/demonstration platform to **support** cyber-informed engineering of controls and hardware systems.

TEDS Process and Instrumentation Diagram (P&ID)



TEDS Design Parameters

- Design Pressure 100 psig
- Design Temperature 340 °C
- Maximum Operating Temperature 325 °C
- Maximum Operating Pressure 14 psig
- Electric Heater Capacity 200 kW
- Nominal Flow Rate 14-33 gpm)
- Working Fluid Therminol 66
- Therminol 66 Properties:
 - wide operating temperature range (-3 to 343°C)
 - low vapor pressure at high temperatures (10.3 psi at 340°C)
 - wide range of material compatibility

MAGNET


To begin initial operation in December 2020



MAGNET Objectives

- Provide a general-purpose, non-nuclear test bed to evaluate microreactor designs
- Provide detailed thermal-hydraulic, performance data for prototypical geometries and operating conditions
 - Test article/flow loop temperature-time histories during start up, shut down, steady state, and off-normal operations
 - Displacement and temperature field data for potential design performance verification and accompanying analytical model validation
- Demonstrate integration of a power conversion unit
- Demonstrate applicability of advanced manufacturing techniques, such as additive manufacturing and diffusion bonding for core and heat removal section designs
- Identify and develop advanced sensors and power conversion equipment including instrumentation and controls for autonomous operation
- Enhance readiness of public stakeholders, particularly DOE laboratories and US NRC, to design, operate, and test high-temperature reactor components

MAGNET P&ID




MAGNET Design Parameters

- Heat removal capacity: 250 kW
- Design pressure: 22 bar
- Hot section design temperature: 650 °C
- Coolant: Compressed N₂ or He
- Heat sink: Chilled water
- Expandable with potential to add power conversion unit or HX interface with collocated system in the future
- Recuperative HX


(Designed with air-Brayton cycle design parameters for temperature and pressure in mind)

Single-Heat-Pipe Preliminary Testing


- Quartz tube will be evacuated and back filled with inert gas
- Flow and ΔT meters allow determination of heat removal rate and comparison to total heater power at steady state
- Recirculated cooling water from 2.5 kW chiller



Process flow diagram for single heat pipe (7-hole hex block) experiments




Quartz tube allows testing in vacuum or inert gas environments



Process flow diagram for single heat pipe (7-hole hex block) experiments

Single-Heat-Pipe Preliminary Testing





- Surrounded by a water-cooled shroud with a gas gap (wire wrap will center the heat pipe inside the shroud)
- Water cooling can support high heat removal rates - greater than the heat pipe rating
- Heat transfer across gap is a combination of radiation and conduction (conduction is dominant)
- Steady-state heat pipe temperature and heat flux can be varied by using He or Ar gas or by varying the length of the condenser section

Printed Circuit Heat Exchanger Testing

Advantages of PCHE-style Heat Exchangers for Microreactor Heat Removal


- High heat transfer coefficients (gas flow in microchannels)
- Inherent suitability for high pressure, high temperature applications
- High heat transfer surface area (extended surface heat transfer)
- Low temperature gradients and thermal stresses through optimized designs
- Lower susceptibility to damage from single-channel flow blockages
- Very low axial temperature gradient
- Uniform heat transfer per unit axial length takes full advantage of entire length of heat removal section of heat pipes

Initial PCHE Design




Process flow diagram for single heat pipe (7-hole hex block) experiments

Initial PCHE Design




Temperature and Stress Fields For Top Platelet


Second PCHE Design (Hybrid Cooling)




1st plate



2nd plate



3rd plate



4th plate


- Design Improvements: (i) Outward Flow Path, (ii) Counter Current Flow (iii) Multiple Inlets, (iv) 3-Way “Counter-Current” Flow Paths
- Flow Path Configuration

5th-8th plates **rotated 120°**
9th-12th plates **rotated 240°**



A total of 12 plates are simulated

Second PCHE Design (Hybrid Cooling)



Temperature and Stress Fields For Top Platelet

Questions?